



Return Duct Kit Assembly

Part No. 4030204



OVER




Therma-Stor[®] LLC

Driven by performance. Powered by design.[™]


4201 Lien Rd., Madison, WI 53704 • TOLL-FREE 1-800-533-7533 • www.thermastor.com • sales@thermastor.com

TS-632c 04/10

Insert front panel tab into hole in the top of dehumidifier.



Install duct collar to the front panel using the four Phillips screws provided.



OVER




Therma-Stor[®] LLC


Driven by performance. Powered by design.[™]

4201 Lien Rd., Madison, WI 53704 • TOLL-FREE 1-800-533-7533 • www.thermastor.com • sales@thermastor.com


Secure the duct/panel assembly to the dehumidifier by engaging the snap buttons into the mating holes on the duct/panel assembly.



Parts List



Phillips Screw, 6-20 x 3/4 - QTY 4



Screw, 4-40 x 1/4 - QTY 2



Nut, 4-40 - QTY 2



Snap Button - QTY 2



Therma-Stor[®] LLC

Driven by performance. Powered by design.[™]

4201 Lien Rd., Madison, WI 53704 • TOLL-FREE 1-800-533-7533 • www.thermastor.com • sales@thermastor.com